

ADDENDUM NO. 2

PROJECT: Contract 124 – 500,000 Gallon WST Repainting (Ground Level)
NEW BID DATE/TIME: **August 6, 2024, at 10:00am**
OWNER: Town of Gainesboro
DATE: July 30, 2024
PROJECT NO.: 24181
NO. OF PAGES: 2

THIS ADDENDUM IS ISSUED TO CLARIFY QUESTIONS RAISED BY BIDDERS AND TO MAKE MODIFICATIONS TO THE SPECIFICATION, PLANS, AND BID DOCUMENTS FOR THIS PROJECT. THE FOLLOWING CHANGES WILL BECOME A PART OF THE CONTRACT DOCUMENTS FOR THIS PROJECT. ACKNOWLEDGE RECEIPT OF THIS ADDENDUM ON THE BID FORM.

NEW BID DATE/TIME: **Please note the new bid date and time is August 6, 2024, at 10:00am**

Bid Schedule: Please replace (Addendum No. 1) BP 124 – 2 of 5 with attached (Addendum No. 2) BP 124 – 2 of 5.

Clarifications:

1. It was brought to our attention that the lead levels indicated in the previous addendum do not meet the threshold to be considered “lead containing”. As such, the CONTRACTOR shall perform cleanup and dispose of the paint and sand blasting debris in accordance with any state, local, and EPA requirements. Containment of tank is still requested to ensure debris and paint does not travel offsite.
2. BID DATE was changed to allow contractors to coordinate to provide pricing on electric mixer.
3. CONTRACTOR shall assume that 120V single phase electricity is available at the site.

THIS ADDENDUM CONSISTS OF TWO (2) PAGES

**** END OF ADDENDUM ****

JAMES C. HAILEY & COMPANY
Consulting Engineers
360 Cool Springs Blvd., Suite 100
Franklin, TN 37067-7216
www.ichengr.com

**ADDENDUM NO. 2
 BID SCHEDULE
 CONTRACT 124 – 500,000 WATER STORAGE TANK REPAINTING (GROUND LEVEL)**

BASE BID – JOHNSON TANK

ITEM NO.	DESCRIPTION	QUANTITY & UNITS	UNIT PRICE		TOTAL AMOUNT
			WORDS	FIGURES	
1	FURNISH & INSTALL SURFACE PREPARATION (FULL BLAST) AND REPAINTING OF TANK INTERIOR	1 LUMP SUM			
2	FURNISH & INSTALL SURFACE PREPARATION (FULL BLAST) AND REPAINTING OF TANK EXTERIOR	1 LUMP SUM			
3	FURNISH & INSTALL SEAM SEALING	1 LUMP SUM			
4	FURNISH & INSTALL TANK DISINFECTION	1 LUMP SUM			
5	FURNISH & INSTALL SITE CLEAN-UP AND RESTORATION	1 LUMP SUM			
6	FURNISH & INSTALL SCREEN AT ROOF VENT AND SECURE	1 LUMP SUM			
7	FURNISH & INSTALL REPLACEMENT "CONFINED ENTRY" PLACARDS	1 LUMP SUM			
8	FURNISH & INSTALL REMOVE AND REAPPLY GROUT AROUND PERIMETER OF TANK (ON CURB) TO DRAW WATER AWAY FROM THE TANK	1 LUMP SUM			
TOTAL BASE BID				(WORDS)	(FIGURES)

(Addendum No. 2) BP 124 – 2 of 5

TO BID, GENERAL CONTRACTORS MUST OBTAIN BID DOCUMENTS FROM ENGINEER.