

Addendum No. 1

For Construction of

REQUEST FOR PROPOSALS – WTP ROOF REPLACEMENT

For The

TOWN OF MONTEREY

In

PUTNAM COUNTY, TENNESSEE

Date: July 1, 2025

BID DATE: July 3, 2025

Bid Time: 2:00 P.M.

THIS ADDENDUM IS ISSUED TO CLARIFY QUESTIONS RAISED BY BIDDERS AND TO MAKE MODIFICATIONS TO THE SPECIFICATIONS, PLANS, AND BID DOCUMENTS FOR THIS PROJECT. THE FOLLOWING CHANGES WILL BECOME A PART OF THE CONTRACT DOCUMENTS FOR THIS PROJECT. **ACKNOWLEDGE RECEIPT OF THIS ADDENDUM ON THE BID FORM.**

Clarifications:

1. It has been brought to our attention that the roof slope is structural, and tapered insulation is not necessary. The proposed EPS thickness shall match existing (1.5" thick).
2. **CONTRACTOR** shall replace existing thru wall flashing (see attached photos for reference).
3. Intention is for final roof product to be a newer version of existing.

THIS ADDENDUM CONSISTS OF ONE (1) PAGE AND TWO (2) PHOTOS.

***** END OF ADDENDUM NO. 1 ******

JAMES C. HAILEY & COMPANY

Consulting Engineers
360 Cool Springs Boulevard, Suite 100
Franklin, Tennessee 37067-7216
(615) 883-4933



