### WEST WILSON UTILITY DISTRICT REQUEST FOR PROPOSALS – FILTER EQUIPMENT

#### ADDENDUM NO. 2

PROJECT:Request for Proposals – Filter EquipmentBID DATE/TIME:July 24, 2025, at 2:00 PM local timeOWNER:West Wilson Utility DistrictDATE:July 17, 2025NO. OF PAGES:3

### **CLARIFICATIONS:**

- 1. PROPOSER shall provide three (3) hard copies and one (1) USB drive including a full electronic copy of PROPOSAL.
- 2. Pre-Approved manufacturers are Leopold and Roberts Filter. Pre-Approval does not absolve PROPOSER from ensuring all necessary documents (as noted in RFP) are included in PROPOSAL submission.
- 3. Filter dimensions are 16.5'x16.5'x12.0' (Approx.).





4. PROPOSER shall provide pricing for a "BASE" Proposal Price for a filter system including twelve (12) total filters. PROPOSER shall provide "DEDUCTIVE" Proposal Pricing for eight (8) total filters. Each Proposal Price shall include the total cost associated with furnishing, shipping, startup, etc... the respective quantity of filters along with all necessary equipment, including, but not limited to: controls, panels, troughs, underdrains, media, air scour, compressors, etc... to ensure a complete and working system.



- 5. PROPOSER shall provide the required number, length, and other associated characteristics of components as required by both TDEC Community Water System Design Criteria and AWWA Standards.
- 6. Certain contract terms may be negotiated (e.g. future costs due to tariffs, material cost increases, etc...).

- 7. OWNER reserves the right to negotiate and purchase equipment direct from PROPOSER (in lieu of including in future Construction Bid) if advantageous to Owner.
- 8. Effluent limits are not required to be included in references.

# THIS ADDENDUM CONSISTS OF THREE (3) PAGES

## \*\*\*\* END OF ADDENDUM \*\*\*\*

JAMES C. HAILEY & COMPANY Consulting Engineers 360 Cool Springs Boulevard, Suite 100 Franklin, Tennessee 37067-7216 www.jchengr.com