

**WEST WILSON UTILITY DISTRICT
REQUEST FOR PROPOSALS - INCLINED PLATE SETTLERS
ADDENDUM NO. 2**

PROJECT: Request for Proposals – Inclined Plate Settlers
BID DATE/TIME: July 24, 2025, at 2:00 PM local time
OWNER: West Wilson Utility District
DATE: July 17, 2025
NO. OF PAGES: 1

CLARIFICATIONS:

1. PROPOSER shall provide three (3) hard copies and one (1) USB drive including a full electronic copy of PROPOSAL.
2. Pre-Approved manufacturers are MRI, JMS, and Sulzer. Pre-Approval does not absolve PROPOSER from ensuring all necessary documents (as noted in RFP) are included in PROPOSAL submission.
3. PROPOSER shall provide pricing for a “BASE” Proposal Price for a “Settler” system including capable of treating 16 MGD. PROPOSER shall provide “DEDUCTIVE” Proposal Pricing a “Settler” system capable of treating 8 MGD. Please note that the basin size is to remain constant (as noted in the RFP) such that the OWNER may add additional “Settler” equipment in the future. Each PROPOSER shall provide an estimate of the total flow rate MGD possible through these basins if “racked out”. Each Proposal Price shall include the total cost associated with furnishing, shipping, startup, etc... the respective capacities along with all necessary equipment, including, but not limited to: plates, plate packs, frames, troughs, etc... to ensure a complete and working system.
4. PROPOSER shall provide the required number, length, and other associated characteristics of components as required by both TDEC Community Water System Design Criteria and AWWA Standards.
5. Certain contract terms may be negotiated (e.g. future costs due to tariffs, material cost increases, etc...).
6. OWNER reserves the right to negotiate and purchase equipment direct from PROPOSER (in lieu of including in future Construction Bid) if advantageous to Owner.
7. OWNER requests that “standard” sizes of materials (plates, plate packs, frames, troughs, etc...) be used.
8. The expectation is that General Contractors will have experience with installation. As such, installation assistance for “Settler” system is not required.
9. Type 316 stainless steel is NOT required unless it is the standard material used.
10. PROPOSER's most current specifications shall be used in the preparation of PROPOSAL.
11. A detailed scope of supply, literature with respect to equipment, and general layout drawings shall be acceptable in lieu of certain deliverables that are typically provided with submittals during the construction process.

THIS ADDENDUM CONSISTS OF ONE (1) PAGE.

**** END OF ADDENDUM ****

JAMES C. HAILEY & COMPANY
Consulting Engineers
360 Cool Springs Boulevard, Suite 100
Franklin, Tennessee 37067-7216
www.jchengr.com